

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

The Airolite Company, LLC P.O. Box 410 Schofield, WI 54476

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code. This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Model SCV660MD Aluminum Louver

APPROVAL DOCUMENT: Drawing No. **SCV660D**, titled "SCV660D", sheets 1 through 9 of 9, dated 12/06/2011, prepared by the manufacturer, signed and sealed by Chander P. Nangia, P.E., bearing the Miami-Dade County Product Control revision stamp with the NOA number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official. This NOA revises NOA # 12-0418.05 and consists of this page 1 and evidence page E-1, as well as approval document mentioned above.

The submitted documentation was reviewed by Carlos M. Utrera, P.E.

MIAMI-DADE COUNTY AFPROVED Africa 104/01/2014

NOA No. 14-0224.09 Expiration Date: October 4, 2017 Approval Date: April 10, 2014 Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Drawing No. **SCV660D**, titled "SCV660D", sheets 1 through 9 of 9, dated 12/06/2011, prepared by the manufacturer, signed and sealed by Chander P. Nangia, P.F.

B. TESTS "Submitted under NOA # 12-0418.05"

- 1. Test reports on: 1) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
 - 2) Large Missile Impact Test per FBC, TAS 201-94
 - 3) Cyclic Wind Pressure Loading per FBC, TAS 203-94 along with marked-up drawings and installation diagram of Model EVH-660D Aluminum Vertical Louvers, prepared by Architectural Testing, Inc, Report No. **B5211.01-602-18**, dated 03/21/2012, signed and sealed by Shawn G. Collins, P.E.
- 2. Test Report on Wind Driven Rain Resistance per TAS 100(A)-95 of a Model EVH-660D Aluminum Vertical Louvers, prepared by Architectural Testing, Inc, Test Report No. **B5211.02-602-18**, dated 03/21/2012, signed and sealed by Shawn G. Collins, P.E.

C. CALCULATIONS "Submitted under NOA # 12-0418,05"

1. Stress, deflection and anchorage calculations prepared by Greenheck Fan Corporation, dated 02/08/2012, signed and sealed by Chander P. Nangia, P.E.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS


1. Statement letter of code conformance to 2010 FBC, issued by Chander P. Nangia, P.E., dated 02/13/2014, signed and sealed by Chander P. Nangia, P.E.


"Submitted under NOA # 12-0418.05"


- 2. No financial interest letter issued by Chander P. Nangia, P.E., dated 04/02/2012, signed and sealed by Chander P. Nangia, P.E.
- 3. Private label agreement dated 01/17/2007.


Carlos M. Utrera, P.E. Product Control Examiner NOA No. 14-0224.09

Expiration Date: October 4, 2017 Approval Date: April 10, 2014









NOTE 1: END GAP MUST COMPLY TO SEALANT MANUFACTURE'S JOINT PERFORMANCE RECOMMENDATIONS.

DESCRIPTION REV # DATE

GAP NOTE & SEALING NOTE 1 02/05/2014 FEB 1 8 2014

No. 21938

PRODUCT REVISED as complying with the Florida Building Code
Acceptance No 4-0224.09
Expiration Date 10/04/70

Mismi Dade Product Control

 \bigcirc


CV660MD

(/)


DETAIL


MULLION

SCV660MD



VIEW OF EXTERIOR FACE OF LOUVER, LOWER RIGHT CORNER







PRODUCT REVISED as complying with the Florida Building Code
Acceptance No 4-7224.09
Expiration Date 10/04/2017

By Miami Dade Product Control

Approved as complying with the Florida Building Code Date 10/04/20/2 NOA# 12-04/8.05 Miami Date Product Covarol By




DARKENED AREAS INDICATE
AREAS SEALED BY FACTORY,
TYP AT BOTH SILL ENDS AND
ALL BLADE—SILL AND JAMB—SILL
FASTENERS. SCREWS ALLOWED
TO USE A GASKET FOR SEALING
VS A "WET" APPLIED SEAL OVER
THE TOP OF THE SCREW.



VIEW OF INTERIOR FACE OF LOUVER, LOWER LEFT CORNER

SEALING DETAIL 1
6 SCALE: 1:2

DARKENED AREAS INDICATE AREAS SEALED BY FACTORY, TYP AT BOTH SILL ENDS.



SECTIONAL VIEW, LOOKING AT SILL

8 SEALING DETAIL 2
6 SCALE: 1:2

SEALING DETAILS

SEALING DETAILS

SCALE

SCALE

SCALE


12/
SCALE

SCALING DETAILS

SCALING DETAILS

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 4-0224.09

No. 21938
No. 21



3,	/8" POWERS	S WEDGE BOL	T FASTENE	R TABLE	
FASTENER NUMBER	· L2A				
DESCRIPTION	3/8" POWERS WEDGE BOLT				
SUBSTRATE	NORMAL WEIGHT CONCRETE			CMU (1.5 KSI GROUT FILLED)	
MINIMUM .	2.5 KSI			6" WIDE, GRADE N, TYPE II, LIGHT/MEDIUM/NORMAL WEIGHT CMU CONFORMING TO ASTM C90	
EDGE DISTANCE (MIN)	2 IN.	3 IN:	4-1/2 IN.	1-1/2 IN.	2 IN.
PENETRATION (MIN)	2-1/8 IN.			2-1/	2 IN.
LOUVER HEIGHT (IN.)	SPACING (IN.)			SPACIN	IG (IN.)
>108 & ≤120	4	6	6	NOT ALLOWED	NOT ALLOWED
>72 & ≤108	6	6	6	NOT ALLOWED	NOT ALLOWED
>36 & ≤72	6	6	6	NOT ALLOWED	6
>0 & ≤36	6	6	6	6	6

1/4" TAPC	ON SCREW	FASTENER TO	48LŁ
FASTENER NUMBER			
DESCRIPTION	1/4" TAPCON		
SUBSTRATE	CONCRETE OR CMU (GROUT FILLED)		
MINIMUM	3.192 KSI CONCRETE OR 3.192 KSI GROUT		
EDGE DISTANCE (MIN)	1 IN.	1-1/2 IN.	2-1/2 IN.
PENETRATION (MIN		1-3/4 IN.	٠,
LOUVER HEIGHT (IN.)	SPACING (IN.)		
>108 & ≤120	5	5	4
>96 & ≤108	5	4	4
>72 & ≤96	2	4	6_
>48 & ≤72	4	6	_ 6
>0 & ≤48	6	6	6

LAG SCREW,	SCREW, &	BOLT W/NU	T FASTENER	TABLE	
FASTENER NUMBER	150	12C 12D		12E	
DESCRIPTION	3/8' LAG SCREW	1/4" LAG SCREW	1/4'-20 SCREW OR BOLT W/		
SUBSTRATE	WOOD		STEEL		
MINIMUM	G=.42		A36 STEEL DR Fy>=36 KSI		
EDGE DISTANCE (MIN)	1-1/2 IN		1/2 IN.		
PENETRATION (MIN)	2-3/4 IN.		16GA (0.06 IN.)	3/16 IN.	
LOUVER HEIGHT (IN.)	SPACING (IN.)		SPACING (IN.)		
>84 & ≤120	6	4	6	6	
>0 & ≤84	6	6	6	6	

CONTINUOUS ANGLE TO	LOUVER FRAME SCREW	
(FASTEN	IER # 11)	
LOUVER HEIGHT (IN.)	SPACING (IN.)	
>84 & ≤120	5	
>0 & ≤84	4	

PRODUCT REVISED as complying with the Florida Building Code
Acceptance No 4-0724 09
Expiration Date 10 04 7017

By Harri Dade Product Control

SCV660MD

 $\dot{}$

 $\overline{\mathbb{Z}}$

99

()

BLE

FASTENER

DATE

Tigot Fi

DESCRIPTION

SEE REVISION NOTE

REV # DATE 1 02/05/2014

REVISION: ALL FOUR FASTENER TABLES ARE UPDATED TO LIMIT MAX ON CENTER SPACING TO 4" FOR FRAME FASTENERS (ITEM 11) AND 6" FOR SUBSTRATE FASTENERS (ITEM 12).

ITEM	· DESCRIPTION	MATERIAL	NOTES
1	LOUVER HEAD	ALUM	
2	LOUVER SILL .	ALUM	
3	LOUVER JAMB	ALUM	
4	LOUVER BLADE	ALUM	3/4" SPACING
5	CONTINUOUS MOUNTING ANGLE	ALUM	AT HEAD AND SILL ONLY
6	BLADE SUPPORT STRAP, FOR HEIGHTS > 60.875" ONLY	ALUM	NOT ATTACHED TO JAMBS
10	#10-24 x 3/4" MIN SCREW	STEEL* /SS	
11	1/4-20 x 1" MIN SCREW	STEEL* \SS	·
12A	3/8" POWERS WEDGE BOLT	STEEL* /SS	SEE FASTENER TABLE PAGE
<u></u>	1/4" TAPCON SCREW	STEEL* /SS	SEE FASTENER TABLE PAGE
	3/8" LAG SCREW	STEEL* \SS	SEE FASTENER TABLE PAGE
12D	1/4° LAG SCREW	STEEL* /SS	SEE FASTENER TABLE PAGE
12E	1/4-20 SCREW OR 1/4-20 BOLT W/NUT	STEEL* /SS	SEE FASTENER TABLE PAGE
	CONCRETE, 2.5 KSI MIN	CONCRETE	NOT BY MANUFACTURER
1	CMU, 1.5 KSI MIN GROUT FILLED	CONCRETE	NOT BY MANUFACTURER
1	STRUCTURAL STEEL, 3/16" MIN	STEEL	NOT BY MANUFACTURER
1	STEEL STUD, 16GA MIN	STEEL	NOT BY MANUFACTURER
20E	WOOD SUBSTRATE, G=0.42 MIN DENSITY	WOOD	NOT BY MANUFACTURER
	·		
	SEALANT, FACTORY APPLIED	VARIES	FACTORY APPLIED
	SEALED SCREW HEAD, FACTORY APPLIED	VARIES	FACTORY APPLIED
1	SHIMS, OPTIONAL, AS REQUIRED, INCOMPRESSIBLE	VARIES	NOT BY MANUFACTURER
33	SEALANT AND BACKER ROD	VARIES	NOT BY MANUFACTURER

(STEEL/STAINLESS-STEEL/ALUMINUM PARTS MAY BE MADE OUT OF ALTERNATE ALLOY THAT HAS EQUAL OR GREATER YIELD STRENGTH)

* STEEL MUST HAVE CORROSION RESISTANT COATING.

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 14-0224-09
Expiration Date 10/04/2017

By
Mismi Dade Product Control

GENERAL NOTES:

- 1. IT SHALL BE THE RESPONSIBILITY OF THE PERMIT HOLDER TO VERIFY THE STRUCTURAL INTEGRITY OF THE EXISTING STRUCTURE TO SUPPORT THE LOADS IMPOSED BY THE PENTHOUSE ASSEMBLY.
- 2. THIS LOUVER HAS BEEN DESIGNED AND TESTED IN ACCORDANCE WITH MIAMI-DADE COUNTY PROTOCOLS [AND QUALIFIED IN ACCORDANCE WITH THE 2010 FLORIDA BUILDING CODE (FBC) AND TEST PROTOCOLS/STANDARDS:

TAS-201 (LARGE MISSILE IMPACT)

TAS-202 (UNIFORM STATIC PRESSURE)

TAS-203 (CYCLIC FATIGUE)

TAS-100(A) (WIND-DRIVEN RAIN)

AMCA STANDARD 550 (WIND-DRIVEN RAIN)

- 3. THIS LOUVER HAS BEEN DESIGNED, TESTED, AND APPROVED TO WITHSTAND DESIGN PRESSURES OF UP TO AND INCLUDING ± 100 PSF.
- 4. THE LOUVER MAY BE INSTALLED IN A LOCATION WHERE THE ROOM BEHIND THE LOUVER IS <u>NOT DESIGNED</u> TO DRAIN WATER PENETRATING INTO THE ROOM OR THE ROOM WILL HOUSE NON-WATER RESISTANT OR WATER PROOF EQUIPMENT, COMPONENTS, OR SUPPLIES.
- 5. THE MAXIMUM SINGLE SECTION SIZE IS 48" WIDE BY 120" HIGH. THE MAXIMUM OVERALL/ASSEMBLED SIZE IS UNLIMITED WIDE (BY USE OF MULTIPLE SECTIONS OF 48" WIDE OR LESS) BY 120" HIGH. SECTIONS/ASSEMBLIES MAY BE STACKED VERTICALLY PROVIDED THERE IS SUITABLE STRUCTURAL SUPPORT (DESIGNED AND INSTALLED BY OTHERS) TO SUPPORT ALL LOADS TRANSFERRED FROM THE LOUVER HEAD AND/OR SILL TO THE SUBSTRATE.
- 6. A HORIZONTAL BLADE SUPPORT STRAP IS REQUIRED IF SECTION HEIGHT IS GREATER THAN 63".
- 7. ALL WOOD SUBSTRATE SHALL BE G = 0.42 DENSITY OR BETTER.
- 8. ALL STEEL STUD SUBSTRATE SHALL BE MIN. 16 GA. FY = 36 KSI.
- 9. ALL STRUCTURAL STEEL SUBSTRATE SHALL BE MIN. 3/16" THICK FY = 36 KSI.
- 10. ALL CONCRETE SUBSTRATE SHALL BE MIN. 2,500 PSI.
- 11. CONCRETE MASONRY SHALL BE MINIMUM OF: 6" WIDE, GRADE N, TYPE II, LIGHT/MEDIUM/NORMAL WEIGHT CMU CONFORMING TO ASTM C90, AND MIN. 1,500 PSI GROUT-FILLED.
- 12. LOUVER CONSTRUCTION: HEAD, SILL, JAMBS, AND BLADES ARE SQUARE CUT AT BOTH ENDS. BLADE SPACING IS 3/4" MAX. BLADES ARE SECURED TO THE HEAD/SILL WITH (2) SCREWS PER BLADE END. EACH JAMB IS SECURED TO THE SILL AND HEAD WITH (2) SCREWS PER JAMB END.
- 13. THE LOUVER MANUFACTURER DOES NOT DETERMINE THE STRUCTURAL INTEGRITY OF THE SUBSTRATE STRUCTURE.
- 14. INSTALLER TO PROVIDE SEPARATION OF DISSIMILAR MATERIALS AS REQUIRED. SEE FL BLDG CODE SECTION 2003.8.4 FOR DETAILS.

MES 12/6/11 SCALE NTS	SHEET NO.	CAD DRAWING NO. SCV660MD
The look that works?" schoffeld, wisconsin 54476	TITLE SCV660MD	DESCRIPTIONS & GENERAL NOTES

Approved as complying with the Florida Building Code
Date 10 104/2012
NOA#_12-0418.05
Minmi Dadg Product Control
By

